

RAF Menwith Hill

On 20 January 2026, RAF Menwith Hill conducted base-wide drinking water sampling for per- and polyfluoroalkyl substances (PFAS), in accordance with DoW policy, “Policy for Monitoring and Treatment of Per- and Polyfluoroalkyl Substances in Department of Defense Drinking Water Systems outside the United States, 28 September 2025.” The table below contains the results of the regulated PFAS detected. For additional guidance on PFAS, use the following link: [ASD\(EI&E\) - Per- and Polyfluoroalkyl Substances \(PFAS\) \(osd.mil\)](#).

PFAS	Result	MCL ¹
PFOA	1.6 ppt	4 ppt
PFOS	1.2 ppt	4 ppt
PFHxS	1.4 ppt	10 ppt
HFPO-DA (GenX)	0 ppt	10 ppt
PFNA	0 ppt	10 ppt
PFBS	0 ppt	N/A ppt
Hazard Index	0.14 (unitless)	1 (unitless)

¹ Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water.